



Town of Plymouth  
**Fire Department**  
 114 Sandwich Street  
 Plymouth, Massachusetts 02360  
 508-830-4213  
 Fax 508-830-4174

## Inspection of Restaurant Use Group Occupancies

Business: \_\_\_\_\_ Certificate No. \_\_\_\_\_

Inspection Item	Comments
Suitable areas are provided for the stationing of fire apparatus for rescue and fire extinguishment purposes and those sufficient unimpeded entrances and exits exist for the entrance of firefighting personnel and the evacuation of the building. All exits and main corridors are free of obstruction and that hazardous materials, if kept in such buildings, shall be located in a place designated by the fire department. (527 CMR 1 18.1)	
Corridors, hallways, and other exit ways are clear of obstacles and hazardous materials which might prevent the timely evacuation of the building or the efficient operation of the firefighting personnel in case of fire or explosion. (527 CMR 1 4.4.3.1)(14.2)	
Hazardous substances shall not be left unattended within 100 feet of any building without a permit from the head of the Fire Department. (527 CMR 1 19.3)	
Certificate of Inspection properly posted {527CMR1 13.1}	
Documentation present for regulated seating {527CMR 1 14.1}	
Sprinkler system properly maintained and within inspection/test requirements {527CMR 1 13.3.3.4.1}	
Fire alarm system properly maintained and within inspection/test requirements {527CMR 1 13.3.3.4.1}	
Documentation showing flame retardant compliance of furnishings with {527CMR1 12.6.3.1}	
Documentation showing flame retardant compliance of decorations with {527CMR1 12.6.2}	
Documentation that employees are trained for emergency procedures {527CMR1 10.9.3.5}	
Egress plans submitted to Fire Department {527CMR1 10.9.2.2}	
All means of egress unobstructed and suited for immediate use {527CMR1 4.4.3.1.1. and 18.1}	
Admittance to facility denied pending corrective action for means of egress {527CMR1 14.1}	
All exit doors operable {527CMR1 14.1 and 19.3}	
In rooms with chairs and tables, aisles to egress door are a minimum of 44" clear width {527CMR1 14.1}	

Inspection Item	Comments
All exit sign lighting operable {527CMR1 4.4.3.2.1} and 14.1}	
Emergency lighting of means of egress operable {527CMR1 4.4.3.2.3}	
Fire extinguishers properly maintained and within inspection date: {527CMR1 4.4.3.2.3}	
Exterior stairways and fire escapes free of snow, ice and obstructions {527CMR1 14.2}	
Check for most recent hood and duct cleaning and ensure cleaner certification and hood diagram are in place {527CMR1 50.5.4 and 50.5.6),2.1}	
Crowd Manager {527 CMR 1 Chap 20} -Are there trained crowd managers? -Are they current with training? -Is daily fire and building safety checklist on site? {527 CMR1 Chap 20}	
EMERGENCY CONTACTS:  1. _____  2. _____  3. _____	